



# OMNIAIRE 2200C

## HEPA Air Filtration Machine

### ORDERING INFO

- OmniAire 2200C
- Primary/Secondary Two-Stage Filters (box of 20)
- HEPA Filter 99.99%, 0.3 $\mu$  (metal frame)
- HEPA FILTER 99.97%, 0.3 $\mu$  (pb frame)
- Bag Filter Housing (includes 1 Bag Filter)
- Bag Filter MERV 15
- Vapor Trap V-bank Filter
- OdorGuard 600 Carbon Filter
- ABS Plastic Intake Manifold, 12" Dia.
- Quick Clamp, 12"-16" Dia.
- Flexible Duct, 12" Dia. x 25' L
- Flexible Duct, Wire & Fiber Reinforced

### PART NUMBER

- OA2200C
- OAP2424
- OAH2424G
- OAH2424L
- HBF2200
- OBF10
- OCVT2424
- OG2424D
- OAIM2200-12
- QCW14
- OAD12
- OAD12R



CONFORMS TO UL STD 507  
CERTIFIED TO CAN/CSA STD  
C22.2 NO. 113-M1984

OmniAire 2200C is a construction grade negative air machine with two speeds, powerful blower and full size, 12" deep HEPA filter. This is a well-constructed and reliable air scrubber with many accessories to remove airborne particulates and bio-contaminants. The 2200C is used to create positive or negative pressure at asbestos, lead and mold abatement projects. For collection of construction dust from cutting or grinding of concrete, wood or plaster, the HEPA filter can be replaced with an economical multi-pocket bag filter. For VOCs and odor control, VaporTrap or OdorGuard activated carbon filters can be quickly installed.

### OmniAire 2200C

<b>Airflow*</b>	1000/2000 CFM
<b>Power Requirements</b>	115 VAC/60 Hz/11.1 Amp
<b>Motor</b>	1.25 HP with thermal overload
<b>Controls</b>	HIGH/OFF/LOW speed switch; amber change filter indicator light; red power indicator light
<b>Filtration</b>	HEPA 99.97%, 0.3 $\mu$ filter; MERV 9 primary/secondary filter Optional: OdorGuard 600 activated carbon filter; VaporTrap V-Bank 36 lbs; HEPA 99.99%, 0.3 $\mu$ filter, MERV 15 bag filter
<b>Housing</b>	galvanized metal, silicone sealed before riveting; 12" outlet; (4) rubber grip handles; (2) 5" hospital grade locking casters, (2) 5" rigid hospital grade casters
<b>Size/Weight</b>	28"W x 32"H x 35"L, 147 lbs.

\*Airflows based on blower manufacturer curves. Different filters may cause the flow to vary.